

Eagles Nest Academy
5005 Cloverlawn Avenue
Flint, MI 48504

Sample Number	Analysis (Pb)	Result (mg/L)	Analysis (Cu)	Result (mg/L)	Sample Description	Site Code
LG00116	Lead	0.000	Copper	0.06	DW002 HALL BY GYM	CA1
LG00117	Lead	0.000	Copper	0.00	DW002 HALL BY GYM	CA2
LG00118	Lead	0.000	Copper	0.00	DW002 HALL BY GYM	CA3
LG00119	Lead	0.000	Copper	0.00	DW002 HALL BY GYM	CA4
LG00120	Lead	0.000	Copper	0.00	DW002 HALL BY GYM	CA5
LG00121	Lead	0.000	Copper	0.00	DW002 HALL BY GYM	CA6
LG00122	Lead	0.000	Copper	0.00	DW002 HALL BY GYM	CA7
LG00123	Lead	0.000	Copper	0.00	DW002 HALL BY GYM	CA8
LG00124	Lead	0.000	Copper	0.00	DW002 HALL BY GYM	CA9
LG00125	Lead	0.000	Copper	0.00	DW002 HALL BY GYM	CA10
LG00126	Lead	0.001	Copper	0.07	CF003 TEACHERS LOUNGE	CB1
LG00127	Lead	0.000	Copper	0.06	CF003 TEACHERS LOUNGE	CB2
LG00128	Lead	0.000	Copper	0.06	CF003 TEACHER LOUNGE	CB3
LG00129	Lead	0.000	Copper	0.06	CF003 TEACHER LOUNGE	CB4
LG00130	Lead	0.000	Copper	0.06	CF003 TEACHERS LOUNGE	CB5
LG00131	Lead	0.000	Copper	0.06	CF003 TEACHERS LOUNGE	CB6
LG00132	Lead	0.000	Copper	0.06	CF003 TEACHERS LOUNGE	CB7
LG00133	Lead	0.000	Copper	0.06	CF003 TEACHERS LOUNGE	CB8
LG00134	Lead	0.000	Copper	0.06	CF003 TEACHERS LOUNGE	CB9
LG00135	Lead	0.000	Copper	0.06	CF003 TEACHERS LOUNGE	CB10
LG00136	Lead	0.006	Copper	0.36	CF003 TEACHERS LOUNGE	P1
LG00137	Lead	0.024	Copper	0.33	CF003 TEACHERS LOUNGE	P2
LG00138	Lead	0.002	Copper	0.07	CF003 TEACHERS LOUNGE	F01
LG00139	Lead	0.000	Copper	0.06	CF003 TEACHER LOUNGE	F02
LG00140	Lead	0.024	Copper	0.76	DW 001 HALLWAY NEAR GYM	P1
LG00141	Lead	0.021	Copper	1.74	DW 001 HALLWAY NEAR GYM	P2
LG00142	Lead	0.003	Copper	0.08	DW 001 HALLWAY NEAR GYM	F01
LG00143	Lead	0.000	Copper	0.00	DW 001 HALLWAY NEAR GYM	F02
LG00144	Lead	0.024	Copper	0.49	DW 002 HALLWAY NEAR GYM	P1
LG00145	Lead	0.001	Copper	0.08	DW 002 HALLWAY NEAR GYM	P2
LG00146	Lead	0.000	Copper	0.00	DW002 HALLWAY NEAR GYM	F01
LG00147	Lead	0.000	Copper	0.00	DW002 HALLWAY NEAR GYM	F02

Note: Results of "Not Detected" have been converted to a numerical value of zero to allow for ease of sorting.

Results in RED exceed 15 ppb for Lead or 1.3 ppm for Copper

1 ppb = 0.001 mg/L

Sampling Date: January 16, 2016

Page 1